


Midas Unit #M12340338, Honeywell Analytics - Windows Internet Explorer  
 http://169.254.60.47

File Edit View Favorites Tools Help  
 Favorites Midas Unit #M12340338, Honeywell Analytics Page Safety Tools



|                       |                    |                                 |          |
|-----------------------|--------------------|---------------------------------|----------|
| <b>Name:</b>          | HA-M12340338       |                                 |          |
| <b>Serial Number:</b> | M12340338          | <b>Cartridge Serial Number:</b> | 12K50491 |
| <b>Location:</b>      | MIDAS Gas Detector |                                 |          |
| <b>IP Address:</b>    | 169.254.60.47      |                                 |          |

**MDA Scientific**  
 Midas Gas Detector  
 Midas Ver 2.12 build 6

**General**

- Status
- Event History
- Calibration Certificate
- Contact Info / Help

**Configuration**

- General
- Gas/Alarms
- Faults
- Network
- Security
- Time/Data

**Calibration**

- Zero Calibration
- Span Calibration
- Flow Calibration
- 4-20 mA Calibration

**Event History:** Events 91 to 100 of 130

| Timestamp                | Type  | Description                                     | Gas | Conc/Data |                         |
|--------------------------|-------|---|-----|-----------|-------------------------|
| Thu Sep 20 19:08:51 2012 | Alarm | ALM2: Alarm Level 2                             | COS | 260       | <a href="#">Details</a> |
| Thu Sep 20 19:08:33 2012 | Alarm | ALM1: Alarm Level 1                             | COS | 158       | <a href="#">Details</a> |
| Thu Sep 20 18:53:45 2012 | Alarm | RST2: Reset Alarm Level 2                       | COS | 0         | <a href="#">Details</a> |
| Thu Sep 20 18:53:45 2012 | Alarm | RST1: Reset Alarm Level 1                       | COS | 0         | <a href="#">Details</a> |
| Thu Sep 20 18:53:29 2012 | Reset | RST : Reset All Faults and Alarms via Web       | COS | 0         | <a href="#">Details</a> |
| Thu Sep 20 18:51:46 2012 | COOL  | COOL : The cartridge temperature                | COS | 26.2      |                         |
| Thu Sep 20 18:51:14 2012 | LOAD  | SAME CELL : Load Data : 12K51530                | COS |           |                         |
| Thu Sep 20 18:47:39 2012 | Fault | F 48 Cartridge Absent                           | COS | S: 8      |                         |
| Thu Sep 20 18:41:49 2012 | Alarm | ALM2: Alarm Level 2                             | COS | 341       | <a href="#">Details</a> |
| Thu Sep 20 18:30:26 2012 | Reset | RST: Not confirmed, returned to previous values | COS |           |                         |

Page 4

Done Internet | Protected Mode: Off 100%